



Product certificate K90258/04

Issued 2020-08-15

Replaces K90258/03

Page 1 of 2

Internal cement mortar lining of pipes

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

CCI Production B.V.

as specified in this product certificate and marked with the Kiwa[®]-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-K778 "Internal cement mortar lining of pipes to be laid underground", dated 2012-02-01.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

287160711

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company
CCI Production B.V.
Fazantweg 5
4791 RR KLUNDERT
Tel. +31 (0)168-323500
info@cci-bv.nl
www.cci-bv.nl



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Internal cement mortar lining of pipes

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

Internal cement mortar lining of pipes in accordance with the assessment guideline BRL-K778 "Internal cement mortar lining of pipes to be laid underground".

This certificate applies to the internal cement-mortar coating of steel pipes of:

- DN 80 to DN 2200.

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

Not applicable to the product.

APPLICATION AND USE

The cement mortar coating is intended for use in new transport pipes for drinking water.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the certificate;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- CCI Production B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.