


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Director: Dr. Thomas-Benjamin Seiler

Legal Entity: Verein des Hygiene-Instituts des Ruhrgebiets e.V.



Hygiene-Institut · PO Box 10 12 55 · DE 45812 Gelsenkirchen · Germany

CCI Leidingsystemen
Fazantweg 5
4749 RR KLUNDERT
THE NETHERLANDS

Address:
Rotthausen Str. 21, DE 45879 Gelsenkirchen

Switchboard +49 (0)209 9242-0
Direct +49 (0)209 9242-237
E-Mail j.albrecht@hyg.de
Internet www.hyg.de

Our reference: W-407362e-25-Alb/Krü
Contact person: Mrs. J. Albrecht

Gelsenkirchen, 10.10.2025

TEST CERTIFICATE

Enhancement of Microbial Growth on Materials to Come into Contact with Drinking water
Test pursuant to DVGW Technical Standard W 270, November 2007

Client: CCI Leidingsystemen
Fazantweg 5
4749 RR KLUNDERT
THE NETHERLANDS

Test material: **Cement Lining of Pipes and Fittings for Drinking Water**

Test method: Material test

Concrete, produced using **Cement Lining of Pipes and Fittings for Drinking Water** is conform to the requirements for the use in the area of drinking water systems pursuant to DVGW Technical Standard W 270 according to test report **W-407362e-25-Alb/Krü** of **10.10.2025**. Details regarding testing procedure and test results are itemized in the test report.

This test certificate is valid from the date of issue and, given that the conditions and legal requirements remain unaltered, expires on **10.10.2030**. The period of validity is 5 years and can be extended upon written request of the client once up to another 5 year term, provided that the specifications of Technical Standard W 270 are met.

for the Director of the Institute

(scanned signature)

Janine Albrecht M. Sc.

Division head Microbiological material and hygiene testing

This document is digitally approved.

The test results refer exclusively to the examined test specimens and the current statutory regulations. The validity of the document expires in case of modifications in the composition of the material or the processing conditions. This document is no DVGW certification. This document shall not be reproduced, except in full, without written approval of the Institute. Our general terms and conditions apply (<http://www.hyg.de>).

Legal Entity: Verein des Hygiene-Instituts des Ruhrgebiets e.V., Register: VR 519 Local Court Gelsenkirchen (Germany); VAT ID: DE125018356

Directorate: Prof. Dr. Jürgen Kretschmann (Head), Andrea Henze, Joachim Löchte, Dr. Frank Obenaus, Dr. Thomas-Benjamin Seiler (Executive Member), Dr. Dirk Waider